

Detailed Latest Test Results



Test Status: All, Test Type: All
Person: All, Instrument: All
From: 27/03/2019 To: 27/03/2020

Client: Crawley Industrial Services Ltd

Site: Van Power Tools

Location: RX67 OPD

Asset ID: 191872	Description: WALKIE TALKIE TRANS	User: PAUL AYLING	Test Instrument: SeawardPrimeTest 300 49B-0175
------------------	----------------------------------	-------------------	---

Test Type	Date	Result	Unit	Status
Visual	27/03/2019			Pass
Insulation Resistance	27/03/2019	> 199	MOhm	Pass
Live Voltage	27/03/2019	245	V	Information
Neutral Voltage	27/03/2019	9	V	Information
Touch Current	27/03/2019	< 0.07	mA	Pass

Overall: Pass

Asset ID: 191873	Description: WALKIE TALKIE TRANS	User: PAUL AYLING	Test Instrument: SeawardPrimeTest 300 49B-0175
------------------	----------------------------------	-------------------	---

Test Type	Date	Result	Unit	Status
Visual	27/03/2019			Pass
Insulation Resistance	27/03/2019	> 199	MOhm	Pass
Live Voltage	27/03/2019	242	V	Information
Neutral Voltage	27/03/2019	9	V	Information
Touch Current	27/03/2019	< 0.07	mA	Pass

Overall: Pass

Asset ID: 191874	Description: WALKIE TALKIE TRANS	User: PAUL AYLING	Test Instrument: SeawardPrimeTest 300 49B-0175
------------------	----------------------------------	-------------------	---

Test Type	Date	Result	Unit	Status
Visual	27/03/2019			Pass
Insulation Resistance	27/03/2019	> 199	MOhm	Pass
Live Voltage	27/03/2019	245	V	Information
Neutral Voltage	27/03/2019	9	V	Information
Touch Current	27/03/2019	< 0.07	mA	Pass

Overall: Pass

Asset ID: 191875	Description: WALKIE TALKIE TRANS	User: PAUL AYLING	Test Instrument: SeawardPrimeTest 300 49B-0175
------------------	----------------------------------	-------------------	---

Test Type	Date	Result	Unit	Status
Visual	27/03/2019			Pass
Insulation Resistance	27/03/2019	> 199	MOhm	Pass
Live Voltage	27/03/2019	245	V	Information
Neutral Voltage	27/03/2019	8	V	Information
Touch Current	27/03/2019	< 0.07	mA	Pass

Overall: Pass

Asset ID: 191876	Description: WALKIE TALKIE TRANS	User: PAUL AYLING	Test Instrument: SeawardPrimeTest 300 49B-0175
------------------	----------------------------------	-------------------	---

Test Type	Date	Result	Unit	Status
Visual	27/03/2019			Pass
Insulation Resistance	27/03/2019	> 199	MOhm	Pass
Live Voltage	27/03/2019	242	V	Information
Neutral Voltage	27/03/2019	9	V	Information
Touch Current	27/03/2019	< 0.07	mA	Pass

Overall: Pass

Asset ID: 191877	Description: REP SAW	User: PAUL AYLING	Test Instrument: SeawardPrimeTest 300 49B-0175
------------------	----------------------	-------------------	---

Detailed Latest Test Results



Test Status: All, Test Type: All
Person: All, Instrument: All
From: 27/03/2019 To: 27/03/2020

Test Type	Date	Result	Unit	Status
Visual	27/03/2019			Pass
Insulation Resistance	27/03/2019	> 199	MOhm	Pass
Overall: Pass				

Asset ID: 191878	Description: HILTI DRILL	User: PAUL AYLING	Test Instrument: SeawardPrimeTest 300 49B-0175	
Test Type	Date	Result	Unit	Status
Visual	27/03/2019			Pass
Insulation Resistance	27/03/2019	> 199	MOhm	Pass
Overall: Pass				

Asset ID: 191879	Description: MILWAUKEE CHARGER	User: PAUL AYLING	Test Instrument: SeawardPrimeTest 300 49B-0175	
Test Type	Date	Result	Unit	Status
Visual	27/03/2019			Pass
Insulation Resistance	27/03/2019	> 199	MOhm	Pass
Live Voltage	27/03/2019	244	V	Information
Neutral Voltage	27/03/2019	8	V	Information
Touch Current	27/03/2019	< 0.07	mA	Pass
Overall: Pass				

Asset ID: 191880	Description: ANGLE GRINDER	User: PAUL AYLING	Test Instrument: SeawardPrimeTest 300 49B-0175	
Test Type	Date	Result	Unit	Status
Visual	27/03/2019			Pass
Insulation Resistance	27/03/2019	> 199	MOhm	Pass
Overall: Pass				

Asset ID: 191881	Description: DEWALT CHARGER	User: PAUL AYLING	Test Instrument: SeawardPrimeTest 300 49B-0175	
Test Type	Date	Result	Unit	Status
Visual	27/03/2019			Pass
Insulation Resistance	27/03/2019	> 199	MOhm	Pass
Live Voltage	27/03/2019	241	V	Information
Neutral Voltage	27/03/2019	8	V	Information
Touch Current	27/03/2019	< 0.07	mA	Pass
Overall: Pass				

Asset ID: 191882	Description: DEWALT CHARGER	User: PAUL AYLING	Test Instrument: SeawardPrimeTest 300 49B-0175	
Test Type	Date	Result	Unit	Status
Visual	27/03/2019			Pass
Insulation Resistance	27/03/2019	> 199	MOhm	Pass
Live Voltage	27/03/2019	243	V	Information
Neutral Voltage	27/03/2019	8	V	Information
Touch Current	27/03/2019	< 0.07	mA	Pass
Overall: Pass				

Asset ID: 191883	Description: MILWAUKEE CHARGER	User: PAUL AYLING	Test Instrument: SeawardPrimeTest 300 49B-0175	
Test Type	Date	Result	Unit	Status
Visual	27/03/2019			Pass
Insulation Resistance	27/03/2019	> 199	MOhm	Pass
Live Voltage	27/03/2019	242	V	Information
Overall: Pass				

Detailed Latest Test Results



Test Status: All, Test Type: All
Person: All, Instrument: All
From: 27/03/2019 To: 27/03/2020

Neutral Voltage	27/03/2019	9	V	Information
Touch Current	27/03/2019	< 0.07	mA	Pass
Overall: Pass				

Asset ID: 191884	Description: MILWAUKEE CHARGER	User: PAUL AYLING	Test Instrument: SeawardPrimeTest 300 49B-0175	
Test Type	Date	Result	Unit	Status
Visual	27/03/2019			Pass
Insulation Resistance	27/03/2019	> 199	MOhm	Pass
Live Voltage	27/03/2019	245	V	Information
Neutral Voltage	27/03/2019	8	V	Information
Touch Current	27/03/2019	< 0.07	mA	Pass
Overall: Pass				

Asset ID: 191885	Description: 110V TRANS	User: PAUL AYLING	Test Instrument: SeawardPrimeTest 300 49B-0175	
Test Type	Date	Result	Unit	Status
Visual	27/03/2019			Pass
Earth Continuity	27/03/2019	0.05	ohm	Pass
Insulation Resistance	27/03/2019	> 199	MOhm	Pass
Live Voltage	27/03/2019	245	V	Information
Neutral Voltage	27/03/2019	9	V	Information
PE Conductor Current	27/03/2019	0.46	mA	Pass
Overall: Pass				

Asset ID: 191886	Description: EXT REEL	User: PAUL AYLING	Test Instrument: SeawardPrimeTest 300 49B-0175	
Test Type	Date	Result	Unit	Status
Visual	27/03/2019			Pass
IEC Lead Continuity	27/03/2019	0.392	ohm	Pass
Insulation Resistance	27/03/2019	> 199	MOhm	Pass
IEC Lead Polarity	27/03/2019			Pass
Overall: Pass				

Asset ID: 191887	Description: 110V EXT LEAD	User: PAUL AYLING	Test Instrument: SeawardPrimeTest 300 49B-0175	
Test Type	Date	Result	Unit	Status
Visual	27/03/2019			Pass
IEC Lead Continuity	27/03/2019	0.046	ohm	Pass
Insulation Resistance	27/03/2019	> 199	MOhm	Pass
IEC Lead Polarity	27/03/2019			Pass
Overall: Pass				

Asset ID: 191888	Description: EXT REEL	User: PAUL AYLING	Test Instrument: SeawardPrimeTest 300 49B-0175	
Test Type	Date	Result	Unit	Status
Visual	27/03/2019			Pass
IEC Lead Continuity	27/03/2019	0.37	ohm	Pass
Insulation Resistance	27/03/2019	> 199	MOhm	Pass
IEC Lead Polarity	27/03/2019			Pass
Overall: Pass				

Total Tests: 17