

Detailed Latest Test Results



Test Status: All, Test Type: All
Person: All, Instrument: All
From: 27/03/2019 To: 27/03/2020

Client: Crawley Industrial Services Ltd

Site: Van Power Tools

Location: RF16 EGZ

Asset ID: 191889	Description: WALKIE TALKIE TRANS	User: PAUL AYLING	Test Instrument: Seaward PrimeTest 300 49B-0175
------------------	----------------------------------	-------------------	---

Test Type	Date	Result	Unit	Status
Visual	27/03/2019			Pass
Insulation Resistance	27/03/2019	> 199	MOhm	Pass
Live Voltage	27/03/2019	245	V	Information
Neutral Voltage	27/03/2019	9	V	Information
Touch Current	27/03/2019	< 0.07	mA	Pass

Overall: Pass

Asset ID: 191890	Description: WALKIE TALKIE TRANS	User: PAUL AYLING	Test Instrument: Seaward PrimeTest 300 49B-0175
------------------	----------------------------------	-------------------	---

Test Type	Date	Result	Unit	Status
Visual	27/03/2019			Pass
Insulation Resistance	27/03/2019	> 199	MOhm	Pass
Live Voltage	27/03/2019	247	V	Information
Neutral Voltage	27/03/2019	9	V	Information
Touch Current	27/03/2019	< 0.07	mA	Pass

Overall: Pass

Asset ID: 191891	Description: WALKIE TALKIE TRANS	User: PAUL AYLING	Test Instrument: Seaward PrimeTest 300 49B-0175
------------------	----------------------------------	-------------------	---

Test Type	Date	Result	Unit	Status
Visual	27/03/2019			Pass
Insulation Resistance	27/03/2019	> 199	MOhm	Pass
Live Voltage	27/03/2019	246	V	Information
Neutral Voltage	27/03/2019	8	V	Information
Touch Current	27/03/2019	< 0.07	mA	Pass

Overall: Pass

Asset ID: 191892	Description: WALKIE TALKIE TRANS	User: PAUL AYLING	Test Instrument: Seaward PrimeTest 300 49B-0175
------------------	----------------------------------	-------------------	---

Test Type	Date	Result	Unit	Status
Visual	27/03/2019			Pass
Insulation Resistance	27/03/2019	> 199	MOhm	Pass
Live Voltage	27/03/2019	244	V	Information
Neutral Voltage	27/03/2019	9	V	Information
Touch Current	27/03/2019	< 0.07	mA	Pass

Overall: Pass

Asset ID: 191893	Description: ANGLE GRINDER	User: PAUL AYLING	Test Instrument: Seaward PrimeTest 300 49B-0175
------------------	----------------------------	-------------------	---

Test Type	Date	Result	Unit	Status
Visual	27/03/2019			Pass
Insulation Resistance	27/03/2019	> 199	MOhm	Pass

Overall: Pass

Asset ID: 191894	Description: MAKITA DRIL	User: PAUL AYLING	Test Instrument: Seaward PrimeTest 300 49B-0175
------------------	--------------------------	-------------------	---

Test Type	Date	Result	Unit	Status
Visual	27/03/2019			Pass
Insulation Resistance	27/03/2019	> 199	MOhm	Pass

Overall: Pass

Detailed Latest Test Results



Test Status: All, Test Type: All
Person: All, Instrument: All
From: 27/03/2019 To: 27/03/2020

Asset ID: 191895	Description: MILWAUKEE CHARGER	User: PAUL AYLING	Test Instrument: SeawardPrimeTest 300 49B-0175	
Test Type	Date	Result	Unit	Status
Visual	27/03/2019			Pass
Insulation Resistance	27/03/2019	> 199	MOhm	Pass
Live Voltage	27/03/2019	248	V	Information
Neutral Voltage	27/03/2019	9	V	Information
Touch Current	27/03/2019	< 0.07	mA	Pass
Overall: Pass				

Asset ID: 191896	Description: MILWAUKEE CHARGER	User: PAUL AYLING	Test Instrument: SeawardPrimeTest 300 49B-0175	
Test Type	Date	Result	Unit	Status
Visual	27/03/2019			Pass
Insulation Resistance	27/03/2019	> 199	MOhm	Pass
Live Voltage	27/03/2019	245	V	Information
Neutral Voltage	27/03/2019	9	V	Information
Touch Current	27/03/2019	< 0.07	mA	Pass
Overall: Pass				

Asset ID: 191897	Description: PANASONIC CHARGER	User: PAUL AYLING	Test Instrument: SeawardPrimeTest 300 49B-0175	
Test Type	Date	Result	Unit	Status
Visual	27/03/2019			Pass
Insulation Resistance	27/03/2019	> 199	MOhm	Pass
Live Voltage	27/03/2019	245	V	Information
Neutral Voltage	27/03/2019	9	V	Information
Touch Current	27/03/2019	< 0.07	mA	Pass
Overall: Pass				

Asset ID: 191898	Description: MILWAUKEE CHARGER	User: PAUL AYLING	Test Instrument: SeawardPrimeTest 300 49B-0175	
Test Type	Date	Result	Unit	Status
Visual	27/03/2019			Pass
Insulation Resistance	27/03/2019	> 199	MOhm	Pass
Live Voltage	27/03/2019	245	V	Information
Neutral Voltage	27/03/2019	9	V	Information
Touch Current	27/03/2019	< 0.07	mA	Pass
Overall: Pass				

Asset ID: 191899	Description: DEWALT CHARGER	User: PAUL AYLING	Test Instrument: SeawardPrimeTest 300 49B-0175	
Test Type	Date	Result	Unit	Status
Visual	27/03/2019			Pass
Insulation Resistance	27/03/2019	> 199	MOhm	Pass
Live Voltage	27/03/2019	243	V	Information
Neutral Voltage	27/03/2019	9	V	Information
Touch Current	27/03/2019	< 0.07	mA	Pass
Overall: Pass				

Asset ID: 191900	Description: REP SAW	User: PAUL AYLING	Test Instrument: SeawardPrimeTest 300 49B-0175	
Test Type	Date	Result	Unit	Status
Visual	27/03/2019			Pass
Insulation Resistance	27/03/2019	> 199	MOhm	Pass
Overall: Pass				

Detailed Latest Test Results



Test Status: All, Test Type: All
Person: All, Instrument: All
From: 27/03/2019 To: 27/03/2020

Asset ID: 191901	Description: 110V TRANS	User: PAUL AYLING	Test Instrument: SeawardPrimeTest 300 49B-0175	
Test Type	Date	Result	Unit	Status
Visual	27/03/2019			Pass
Earth Continuity	27/03/2019	0.11	ohm	Pass
Insulation Resistance	27/03/2019	> 199	MOhm	Pass
Live Voltage	27/03/2019	245	V	Information
Neutral Voltage	27/03/2019	8	V	Information
PE Conductor Current	27/03/2019	0.43	mA	Pass
Overall: Pass				

Asset ID: 191902	Description: 110V EXT LEAD	User: PAUL AYLING	Test Instrument: SeawardPrimeTest 300 49B-0175	
Test Type	Date	Result	Unit	Status
Visual	27/03/2019			Pass
IEC Lead Continuity	27/03/2019	0.368	ohm	Pass
Insulation Resistance	27/03/2019	> 199	MOhm	Pass
IEC Lead Polarity	27/03/2019			Pass
Overall: Pass				

Total Tests: 14